

**DECLARATION OF PERFORMANCE (DoP)
N° 1075/18**

| | |
|-------------------------------|--|
| • Product type | FS18OR18 300/500 V - REPERO® power |
| • Intended use | Cables for the distribution of electrical power, control and telecommunications, installed in residential buildings or other civil construction, subjected to the requirements for reaction to fire. |
| • Manufacturer | Baldassari Cavi Viale Europa 118/220 55013 Lammari - Capannori (Lucca) - Italy Tel. +39 0583 43521 www.baldassaricavi.it |
| • AVCP System | 1+ |
| • Harmonized Standard | EN 50575:2014 + A1:2016 |
| • Notified Body | NB 0051 |
| • Reaction to fire | C _{ca} - s3, d1, a3 |
| • Hazardous substances | NPD |

The above mentioned product performance complies with the declared reaction of fire.
This declaration of performance has been issued, in accordance with Regulation (EU) n° 305/2011,
under the sole responsibility of the manufacturer mentioned above.

Signed on behalf of the manufacturer:
Chief Operating Officer, M. Ing. Luca Dossena

Lucca, November 6th, 2018

**DECLARATION OF PERFORMANCE (DoP)
N° 1075/18**

| | |
|-------------------------------|--|
| • Product type | FS18OR18 300/500 V - REPERO® signalling and control |
| • Intended use | Cables for the distribution of electrical power, control and telecommunications, installed in residential buildings or other civil construction, subjected to the requirements for reaction to fire. |
| • Manufacturer | Baldassari Cavi Viale Europa 118/220 55013 Lammari - Capannori (Lucca) - Italy Tel. +39 0583 43521 www.baldassaricavi.it |
| • AVCP System | 1+ |
| • Harmonized Standard | EN 50575:2014 + A1:2016 |
| • Notified Body | NB 0051 |
| • Reaction to fire | C _{ca} - s3, d1, a3 |
| • Hazardous substances | NPD |

The above mentioned product performance complies with the declared reaction of fire.
This declaration of performance has been issued, in accordance with Regulation (EU) n° 305/2011,
under the sole responsibility of the manufacturer mentioned above.

Signed on behalf of the manufacturer:
Chief Operating Officer, M. Ing. Luca Dossena

Lucca, November 6th, 2018