

# LICENCE

No. 20858 replaces No.20112

Issued to:

Applicant:

**Bruno Baldassari and F.LLI. S.p.A.**  
**Loc. Sardegna, Viale Europa, 118/120**  
**55013 LAMMARI-CAPANNORI (LUCCA)**  
**Italy**

Licensee:

**Bruno Baldassari and F.LLI. S.p.A.**  
**Loc. Sardegna, Viale Europa, 118/120**  
**55013 LAMMARI-CAPANNORI (LUCCA)**  
**Italy**



Product : cables for fixed wiring

Trade name(s) : BALDASSARI

Type(s)/model(s) : XVB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 967

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 12/06/2018



ir. C. Lana,  
 Certification Manager

© Only integral publication of this certificate, including the annex, is allowed  
 This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	:	cables for fixed wiring
Trade name(s)	:	BALDASSARI
Type(s)/Model(s)	:	XVB
description	:	cable with copper conductors, unarmoured
insulating material	:	XLPE insulated and sheathed with PVC
rated voltage Uo/U	:	0.6/1 kV
Fire propagation	:	minimum Cca-s3,d2,a3

**Additional information**

Covered number of conductors (Round type) and cross sections

- 1-core : 10 mm<sup>2</sup> to 240 mm<sup>2</sup>
- 2-core: 1.5 mm<sup>2</sup> to 35 mm<sup>2</sup>
- 3 -core: 1.5 mm<sup>2</sup> to 50 mm<sup>2</sup>
- 4-core: 1.5 mm<sup>2</sup> to 50 mm<sup>2</sup>
- 5-core: 1.5 mm<sup>2</sup> to 25 mm<sup>2</sup>

**TESTS****Test requirements**

NBN HD 604:2016

**Test results**

The test results are laid down in certification file ref. 628989/01

**Remarks**

This certificate is based on test reports ref. 616386.01a, 616386.01b, 616386.01c and 528C




**Conclusion**

The examination proved that all test requirements were met.

Checked by, project leader : Luigi Zanutto - 12/06/2018

Department Manager,  
Product Certification :

Certification Manager :

A handwritten signature in blue ink, followed by the date '2018-06-12'.

**FACTORY LOCATION(S)**

Bruno Baldassari and F.LLI. S.p.A.  
Loc. Sardegna, Viale Europa, 118/120  
55013 LAMMARI-CAPANNORI (LUCCA)  
Italy