

Page 1 of 2

Certificate No: LR2002705TA Issue Date: 03/04/2020 Expiry Date: 06/03/2024

## **Type Approval Certificate**

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer Bruno Baldassari & F.lli S.p.A.

Address Viale Europa 118/120, Lammari - Capannori (Lucca), 55013, Italy

**Type** Cables

**Description** Flexible single-core cable for internal wiring for maximum conductor

temperature of 90°C, PVC compound insulation, TI3 quality.

Type: H07V2-K 07V2-K

**Application** Fixed cabinetinternal wiring. H07V2-K

Forinternal wiring and for fixed and protected installation. 07V2-K

**Specified Standard** EN 50525-1:2012 EN 50525-2-31:2012

**Ratings** Rated Voltages Uo/U[V]: 450/750 V

Maximum rated conductor temperature: 90°C

RANGE: Number of Cores: Cross Sectional Area [mm2]:

Single: 1 1.50 - 35 1 1.50 - 240

**Other Conditions** This Certificate is intended as the extension of Type Approval Certificate

19/00030, which details remain unchanged and to which this Certificate

should be attached

**Matt Higgins** 

Electrical Specialist to Lloyd's Register EMEA A member of the Lloyd's Register Group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2

Certificate No: LR2002705TA Issue Date: 03/04/2020 Expiry Date: 06/03/2024

## **Type Approval Certificate**

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. LR2002705DA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.





